

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001


No.F6/DFS/MS/School/2021/SZ/

765

Dated: 21/9/21

FIRE SAFETY CERTIFICATE

Certified that the Satya Public School, Qutub Vihar, Main Road Goyla Dairy, New Delhi-71, Comprised of Ground plus one upper floor only, owned/occupied by Satya Public School was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/2011/960 Dt.- 24/05/2011. The school building was re-inspected by the officer concerned of this department on dated 13/09/2021 in the presence of Smt. Kusum Lata (Principal) and found that the School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and found that the building is fit for occupancy Group B 'Educational Building' with effect from 21/9/21..... for a period of three years, subject to conditions printed overleaf.
Issued on.....21/9/21.....at New Delhi by


(Sunil Chawdhary)
Dy.Chief Fire Officer

Copy to:-

1. The Principal
Satya Public School,
Qutub Vihar , Goyla Dairy Main Road, New Delhi-110071.
2. Director of Education,
Govt. of N.C.T. Delhi, Old Secretariat, New Delhi-54.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.